


Defense Distribution Susquehanna Pennsylvania

Recording Form for ACBM Physical and Hazard Assessment Data

Date: 4/18/13

Inspector Initials: TJO/DJH

Building Number: 67	Building Use: Admin General Purpose	
Functional Space: Admin/Common Areas	Location: 1001	
Type of ACBM/Assumed ACBM: <input type="checkbox"/> Surfacing <input type="checkbox"/> TSI <input checked="" type="checkbox"/> Miscellaneous Description: 12"x12" Floor Tile, White, Gray Streaks		
Approximate Amount of Material (linear or square feet): 600 ft ²		
Friability: <input type="checkbox"/> Friable <input checked="" type="checkbox"/> Nonfriable		
Condition: Percent Damage: 0-1% <input type="checkbox"/> Localized <input checked="" type="checkbox"/> Distributed		
Type of Damage: <input type="checkbox"/> Deterioration <input type="checkbox"/> Water <input checked="" type="checkbox"/> Physical Description: None		
Overall Rating: <input checked="" type="checkbox"/> Good <input type="checkbox"/> Damaged <input type="checkbox"/> Significantly Damaged		
Potential for Disturbance: Frequency of Potential Contact: <input type="checkbox"/> High <input type="checkbox"/> Moderate <input checked="" type="checkbox"/> Low Description:		
Influence Of Vibration: <input type="checkbox"/> High <input type="checkbox"/> Moderate <input checked="" type="checkbox"/> Low Description:		
Potential for Air Erosion: <input type="checkbox"/> High <input type="checkbox"/> Moderate <input checked="" type="checkbox"/> Low Description:		
Overall Rating: <input type="checkbox"/> Potential for Significant Damage <input type="checkbox"/> Potential for Damage <input checked="" type="checkbox"/> Low Potential		
AHERA Hazard Assessment Ranking: <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5 <input type="checkbox"/> 6 <input type="checkbox"/> 7 (See back for key)		
Comments: Apply coat of wax		
Signed: 		Date: 5/7/13

AHERA Hazard Assessment Rankings

Hazard Rank	ACBM Condition	ACBM Disturbance Potential
7	Significantly Damaged	Any
6	Damaged	Potential for Significant Damage
5	Damaged	Potential for Damage
4	Damaged	Low
3	Good	Potential for Significant Damage
2	Good	Potential for Damage
1	Good	Low



Table D.2 Confirmed/Assumed ACM in 57 Buildings: Pre-2000 through 2007 Construction (Continued)

Building: 00067

HM ID: M00067.004.A - (004.A) 12" x 12" Floor Tile, White, Gray Streaks



Material Category: Misc.

How Identified as ACM: Sampled

Material Location	Material Quantity	Material Condition	Recommended Response Action	Room, ID
Level 1, Room 1001, Office	600 S.F.	Good	O&M Program	R00067.1.1001

BUILDING 66 (1,340 SF)

1" = 10'-0"




- FLOORING MATERIAL
- TSI
- OTHER MISCELLANEOUS
- SURFACING MATERIAL
- ROOFING MATERIAL

- LEVEL 0 - CRAWL SPACE, MECHANICAL AREA, OR BASEMENT
- LEVEL 1 - 1ST FLOOR
- LEVEL 2 - 2ND FLOOR
- LEVEL 3 - 3RD FLOOR
- LEVEL M - MEZZANINE LEVEL
- LEVEL A - ATTIC LEVEL
- LEVEL R - ROOF LEVEL

BUILDING 67 (1,340 SF)

1" = 10'-0"



DESCRIPTION	DATE	APPR.

1.060SF)