

Building	Location	Current Steam Trap Installed										Recommended Trap Replacement				Repair Made	
		FL	Tag	Elev	Size	Type	Mfg	Model	Psig	Equip.	Test	Comments	Qty	Size	Type	Model	Repaired or Tested
1	Service Room	B	117	5	3/4"	TD	SO	52	25	Drip	FC	1	3/4"	FTI	I-2030-3		
1	Service Room	B	119	2	1/2"	TD	SO	52	25	Drip	FO	1	1/2"	FTI	I-2030-2		
1	Service Room	B	132	4	3/4"	TD	SO	TD52	80	Drip	LK	1	3/4"	BKT	8000-125		
1	S41 Mech Rm	5	261	2	3/4"	BKT	SO	B1H	25	Drip	LK	1	3/4"	FTI	I-2030-3		
1	A Side Attic	6	248	5	3/4"	FT	SO	FT15	20	HUH	FO	1	3/4"	FT	2030-3		
1	B Side Attic	6	258	6	3/4"	FT	SO	FT30	20	HUH	FO	1	3/4"	FT	2030-3		
2	Basement	B	221	5	3/4"	UTD	SO	52	10	Drip	FO	1	3/4"	FTI	I-2030-3		
2	Attic	4	217	4	3/4"	BKT	AG	811	10	Drip	LK	1	3/4"	FTI	I-2030-3		
3	Storage in pit	B	352	-2	1/2"	TD	SO	52	5	Drip	FO	1	1/2"	FTI	I-2030-2		
4	Mech Rm	B	349	3	1/2"	TD	SO	TD52	80	Drip	LK	1	1/2"	BKT	8000-125		
5	Mech Rm	B	347	7	1/2"	TD	SO	52	5	Drip	FC	1	1/2"	FTI	I-2030-2		
6	Mech	B	83	7	3/4"	FTI	SO	FT15	5	HUH	LK	1	3/4"	FTI	I-2030-3		
7	Storage 2	B	75	6	3/4"	FT	SO	FT15	10	Drip	LK	1	3/4"	FT	2030-3		
7	Pipe storage	B	77	5	3/4"	FT	SO	FT15	10	Drip	LK	1	3/4"	FT	2030-3		
7	Pipe storage pit	B	78	-2	3/4"	TD	SO	TD52	80	Drip	LK	1	3/4"	BKT	8000-125		
7	SW corner	G	SW	15	3/4"	FT	SO	FT15	10	HUH	FO	1	3/4"	FT	2030-3		
7	By machines	G	M	8	3/4"	FT	SO	FT15	10	HUH	LK	1	3/4"	FT	2030-3		
10	Basement pump	B	146	5	1/2"	UTD	SO	TD52	100	Drip	LK	1	1/2"	BKT	8000-125		
10	Tunnel entrance	B	150	1	1/2"	UTD	SO	TD52	100	Drip	FO	1	1/2"	BKT	8000-125		
10	Boiler storage	G	143	9	3/4"	BKT	SO	B1H	40	VUH	FO	1	3/4"	BKT	8000-125		
10	Chiller	G	154	9	1"	FT	SO	30	40	HUH	FO	1	1"	BKT	8011-200		
10	Chiller	G	158	15	1"	FT	SO	30	40	HUH	LK	1	1"	BKT	8011-200		
10	Chiller	G	159	15	3/4"	FT	SO	30	40	HUH	FO	1	3/4"	BKT	8000-125		
17	Service Room	B	315	4	1/2"	TD	SO	52	25	Drip	LK	1	1/2"	FTI	I-2030-2		
17	Service Room	B	318	3	1/2"	TD	SO	52	25	Drip	FO	1	1/2"	FTI	I-2030-2		
17	Crawl	B	332	4	3/4"	BKT	WM	1031	80	Drip	FC	1	3/4"	BKT	8000-125		
17	Stairs 3 Crawl	B	333	4	1/2"	TD	SO	TD52	80	Drip	LK	1	1/2"	BKT	8000-125		
17	Stairs 3 Crawl	B	335	5	3/4"	FT	SO	FT15	5	Drip	FO	1	3/4"	FT	2030-3		
17	Stairs 3 Crawl	B	341	2	1"	FT	WM	FT30	20	Drip	FO	1	1"	FT	2030-4		
17	Attuc	5	282	3	1/2"	TD	SO	52	20	Drip	LK	1	1/2"	FTI	I-2030-2		
17	Attuc	5	289	1	1 1/4"	FT	MEP	44-530	10	STS	FO	1	1 1/4"	FT	2030-5		
17	Attuc	5	294	5	3/4"	FT	NN	FTN	25	HUH	LK	1	3/4"	FT	2030-3		
17	Attic	5	304	1	1/2"	FTI	SO	FT15	12	Drip	FO	1	1/2"	FTI	I-2030-2		
17	Attic	5	309	5	3/4"	FT	NN	FTN	25	HUH	LK	1	3/4"	FT	2030-3		
18	Service Room	B	189	5	1/2"	UTD	SO	52	25	Drip	FC	1	1/2"	FTI	I-2030-2		
18	Service Room	B	190	6	3/4"	FT	SO	FT15	25	Drip	FC	1	3/4"	FT	2030-3		
18	Service Room	B	193	5	3/4"	FT	SO	FT15	5	Drip	FO	1	3/4"	FT	2030-3		
18	Tunnel	B	201	2	1"	FT	SO	FT15	5	Drip	FO	1	1"	FT	2030-4		
18	Tunnel	B	202	2	1"	FT	SO	FT15	5	Drip	LK	1	1"	FT	2030-4		
18	Tunnel	B	203	2	3/4"	FT	SO	FT15	5	Drip	FC	1	3/4"	FT	2030-3		
18	Roof Access 1	1	184	3	1 1/4"	FT	NN	FTN	25	AHU	FO	1	1 1/4"	FT	2030-5		
18	Attic A Side	5	162	4	3/4"	BKT	NN	805	25	Drip	LK	1	3/4"	FTI	I-2030-3		
18	Attic A Side	5	165	3	2"	FT	NN	FTN	25	HEX	LK	1	2"	FT	2030-8		
18	Attic A Side	5	166	4	3/4"	BKT	NN	805	25	Drip	LK	1	3/4"	FTI	I-2030-3		
18	B Side	5	174	1	3/4"	FT	NN	FTN	15	Drip	FO	1	3/4"	FT	2030-3		
19	Basement	B	16	3	1/2"	TD	SO	52	25	Drip	FO	1	1/2"	FTI	I-2030-2		
19	Basement	B	20	1	1/2"	FTI	SO	30	25	Drip	LK	1	1/2"	FTI	I-2030-2		
19	Crawl	B	24	3	3/4"	FT	SO	FT15	5	Drip	LK	1	3/4"	FT	2030-3		
19	Attic Mech	A	1	4	3/4"	FT	SO	30	25	Drip	FO	1	3/4"	FT	2030-3		
22	Basement	B	41	3	1/2"	TD	SO	52	15	Drip	FO	1	1/2"	FTI	I-2030-2		
22	Basement	B	42	4	1/2"	TD	SO	52	15	Drip	FO	1	1/2"	FTI	I-2030-2		
22	Basement	B	49	9	3/4"	FT	SO	FT15	5	Drip	LK	1	3/4"	FT	2030-3		
23	118	B	58	7	1"	FTI	AG	B4	25	Drip	LK	1	1"	FTI	I-2030-4		
23	118	B	62	4	1/2"	BKT	AG	TVS811	80	Drip	FO	1	1/2"	BKT	8000-125		
23	Roof access AHU 1	R	63	3	3/4"	FT	AG	B3	25	Drip	NT	1	3/4"	FT	2030-3		
23	Roof access AHU 1	R	64	3	3/4"	FT	AG	B3	25	AHU	NT	1	3/4"	FT	2030-3		
23	Roof access AHU 2	R	65	3	3/4"	FT	AG	B3	25	AHU	FC	1	3/4"	FT	2030-3		
23	Roof access AHU 3	R	66	3	3/4"	FT	AG	B3	25	AHU	NT	1	3/4"	FT	2030-3		
24	Mech	B	34	4	1/2"	TD	SO	52	25	Drip	LK	1	1/2"	FTI	I-2030-2		
24	Mech	B	37	9	1/2"	TD	SO	52	25	Drip	FC	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	S	20	1/2"	TD	SO	52	25	VUH	NT	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	S	20	1/2"	TD	SO	52	25	VUH	NT	0					
24	Gymnasium	1	E	20	1/2"	TD	SO	52	25	VUH	NT	2	traps parallel per VUH				
24	Gymnasium	1	E	20	1/2"	TD	SO	52	25	VUH	NT	0					
24	Gymnasium	1	NE	20	1/2"	TD	SO	52	25	VUH	NT	2	traps parallel per VUH				
24	Gymnasium	1	NE	20	1/2"	TD	SO	52	25	VUH	NT	0					
24	Gymnasium	1	NE	20	1/2"	TD	SO	52	25	Drip	NT	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	N	20	1/2"	TD	SO	52	25	VUH	NT	2	traps parallel per VUH				
24	Gymnasium	1	N	20	1/2"	TD	SO	52	25	VUH	NT	0					
24	Gymnasium	1	N	20	1/2"	TD	SO	52	25	VUH	NT	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	N	20	1/2"	TD	SO	52	25	Drip	NT	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	N	20	3/4"	FTI	SO	30	25	ZRH	NT	1	3/4"	FTI	I-2030-3		
24	Gymnasium	1	NW	20	1/2"	TD	SO	52	25	VUH	NT	2	traps parallel per VUH				
24	Gymnasium	1	NW	20	1/2"	TD	SO	52	25	VUH	NT	0					
24	Gymnasium	1	W	20	1/2"	TD	SO	52	25	VUH	NT	2	traps parallel per VUH				
24	Gymnasium	1	W	20	1/2"	TD	SO	52	25	VUH	NT	0					
24	Gymnasium	1	W	20	1/2"	TD	SO	52	25	Drip	NT	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	W	20	1/2"	FTI	SO	30	25	Drip	NT	1	1/2"	FTI	I-2030-2		
24	Gymnasium	1	W	20	3/4"	FTI	SO	30	25	ZRH	NT	1	3/4"	FTI	I-2030-3		
24	Outside access	1	39	2	1"	FT	SO	30	20	Drip	NT	1	1"	FT	2030-4		
24	Outside access	1	40	6	1"	FT	SO	30	20	Drip	NT	1	1"	FT	2030-4		
101	14 Mech Rm	G	274	4	1 1/4"	FT	SO	FT30	20	HEX	FO	1	1 1/4"	FT	2030-5		
104	Mech Rm	B	228	1	1/2"	TD	SO	TD52	80	Drip	FO	1	1/2"	BKT	8000-125		
104	Mechanical Room	3	84	3	3/4"	FT	SO	FT15	80	Drip	LK	1	3/4"	BKT	8000-125		
104	Mechanical Room	3	86	3	1 1/4"	FT	SO	FT15	80	Drip	FO	1	1"	BKT	8011-200		
104	Mechanical Room	3	87	3	1 1/4"	FT	SO	30	25	Drip	LK	1	1"	FT	2030-4		
104	Mechanical Room	3	96	1	3/4"	BKT	AG	811	80	Drip	FO	1	3/4"	BKT	8000-125		
104	Mechanical Room	3	99	2	3/4"	BKT	AG	811	10	Drip	FO	1	3/4"	FTI	I-2030-3		

104	Mechanical Room	3	103	5	3/4"	FT	PEN	PT63	10	Drip	LK	1	3/4"	FT	2030-3
104	Mechanical Room	3	105	3	3/4"	BKT	AG	811	10	Drip	FO	1	3/4"	FTI	I-2030-3
104	Mechanical Room	3	116	3	1 1/2"	FTI	AG	125	80	HEX	LK	1	1 1/2"	FTI	I-2125-6
106	Service Room	G	54	4	1"	TD	SO	TD52	80	Drip	LK	1	1"	BKT	8011-200
136	In service room	G	69	2	3/4"	FT	SO	30	25	Drip	LK	1	3/4"	FT	2030-3
136	In service room	G	70	2	3/4"	FT	NN	FTN	25	Drip	FO	1	3/4"	FT	2030-3