

Two Valve Isolation Per VA Directive 1810 Appendix A, 3.F

Please note that the contractor is to ensure two isolation valves are supplied and installed in all HPS, MPS and LPS steam piping per the below description in VHA Directive 1810 Appendix A, 3.F

“Any time maintenance and construction work is performed on steam systems, two valve isolation is required (closed position) in series between the steam and the work being performed. This applies to all HP steam as well as LP steam lines 2 inches or larger and hot water systems where the temperature of the operating fluid is at or greater than 257 degrees Fahrenheit.”