

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE 1 OF PAGES 2

2. AMENDMENT/MODIFICATION NUMBER
00013. EFFECTIVE DATE
12-11-2024

4. REQUISITION/PURCHASE REQ. NUMBER

5. PROJECT NUMBER (if applicable)
503-25-1026. ISSUED BY
Department of Veterans Affairs
Network Contracting Office 4

CODE

00244

7. ADMINISTERED BY (If other than Item 6)

CODE

00244

Department of Veterans Affairs
Network Contracting Office 4

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

36C24425R0025

9B. DATED (SEE ITEM 11)
11-07-2024

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

 A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: D. OTHER (Specify type of modification and authority)**E. IMPORTANT:** Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The above numbered solicitation for "Install Generator Fencing" is amended as follows:

See pages 2-4 for submitted RFI's and answers.

Proposals shall be submitted electronically to Kenniesha.Coleman@va.gov and Christopher.McDevitt@va.gov NLT 11:00 AM EST on 12-18-2024.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

Christopher McDevitt
Contracting Officer

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

(Signature of Contracting Officer)

**Project 503-25-105, Install Generator Fencing – Altoona
RFIs and Answers**

#	Question	VA Final Answer
1	The details, drawings and specifications call for Impasse II Series by Ameristar Fence. However, the passive barrier spec calls for a "crash rated fence". Impasse II is anti-climb but not M-rated passive barrier. Please clarify what is desired?	Specifications for the crash rated fence are located in the PSDRM 2022 Section 7.5, attached for reference.
2	The detail CS-504/ 10 shows a gate operator on the double gate. However, the specs clearly say double vehicle gates are manually operated. (Spec 32 31 40 - 3/ Part 2.4 - C) Also there is no automation called out in the specs. Alternate #1 calls for a card reader on the man gates.	The drawings are revised to match specifications to have vehicle gates manually operated. All gates shown on plan are called out to have card reader for alternate #1.

Nothing Follows

See attached document: 503-25-102 Install Generator Fencing Drawings Revision 1 12-10-2024.

See attached document: Physical Security Design Manual- July2022.

End of Document