

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF	PAGES 2
---	---------	---------------------	-----------	----	------------

2. AMENDMENT/MODIFICATION NUMBER 0004	3. EFFECTIVE DATE 01-15-2025	4. REQUISITION/PURCHASE REQ. NUMBER	5. PROJECT NUMBER (if applicable) 503-25-102
--	---------------------------------	-------------------------------------	---

6. ISSUED BY Department of Veterans Affairs Network Contracting Office 4	CODE 00244	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Office 4	CODE 00244
--	---------------	---	---------------

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders	(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C24425R0025
	<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11)
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 01-24-2025 11:00 AM EST

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The above numbered solicitation for "Install Generator Fencing" is amended as follows:

See page 2 for submitted design clarification RFI and answer.

The proposal due date is extended to 1-24-2025 at 11:00 AM EST.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Christopher McDevitt Contracting Officer
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)
15C. DATE SIGNED	16C. DATE SIGNED

Project 503-25-105, Install Generator Fencing – Altoona

RFIs and Answers

A0002

Question	VA Final Answer
<p>The amended specs states the fence would need to stop a 4,000 lb. vehicle at a speed of a 30 MPH with a max penetration distance of 3.3'. This would be a PU30 P1 system. Is it permissible to use a M30 P1 system? The shortest run available for the M30 P1 would be 24'. If not, could we add standalone bollards to meet the rating?</p>	<p>The PSDRM Section 7.5 that was referenced in response to RFI 002 also states to follow ASTM F2656. Looking at ASTM F2656 it shows that the PU30 system is sufficient for the design parameters. The VA would like to use the fence that that meets the design criteria of PSDRM 7.5 in the most efficient manner.</p>

Nothing Follows
End of Document