AMENDMENT OF SOLICITATION/MODIFIC	T BPA NO.	NO. 1. CONTRA		NTRACT ID CODE		OF PAGES	
2. AMENDMENT/MODIFICATION NUMBER 0002	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NUMBER			5. PROJECT NUMBER (if applicable) $642-22-104$		
6. ISSUED BY	36C244	7. ADMINISTERED BY (If other than Item 6) CODE 36C244					
Department of Veterans Affairs Network Contracting Office 4 VA Medical Center 3900 Woodland Avenue Philadelphia, Pa, 19104	kevin.rodgers2@va.gov						
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, S		(X)	9A. AMENDMENT OF SOLICITATION NUMBER				
To all Offerors/Bidders		36C24425R0041					
				9B. DATED (SEE ITEM 11)			
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER			
				10B. DATED (SEE ITEM 13)			
CODE FACILITY CODE							
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
offer submitted; or (c) By separate letter or electronic com ACKNOWLEDGMENT TO BE RECEIVED AT THE PLAC RESULT IN REJECTION OF YOUR OFFER. If by virtue or electronic communication, provided each letter or elect the opening hour and date specified. 12. ACCOUNTING AND APPROPRIATION DATA (If required)	E DESIGNATED FOR THE I of this amendment you desire	RECEIPT OF OFFERS PRIC e to change an offer already	OR TO	O THE HOUR AND DATE nitted, such change may	E SPE0	CIFIED MA de by letter	Υ
	ES ONLY TO MODIFICA			•			
CHECK ONE A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify at							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR		ANGES (such as changes in pages)	ying off	ice, appropriation date, etc.)			
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSU	JANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor is not, X is required to sign this document and return copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UC Project Title: 36C24425R0041 642-22- 1. The purpose of this amendment is to	-	station Upgrade Pha	se 1				
Except as provided herein, all terms and conditions of the document reference	ed in Item 9A or 10A, as heretofore char	nged, remains unchanged and in full fo	rce and	d effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRA Kaitlyn House Contracting Offic						
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA			16	6C. DATE SIG	NED
(Signature of person authorized to sign)	·	(Signature of	f Contra	acting Officer)	_		

RFI 1: 642-22-104, 36C24425R0041, Bldg 2 Substation Upgrade Phase 1

1. During the Site Visit, the VA stated that there is no Option #1, meaning the Temporary Substation will be permanent. Drawing A-101 talks about Options. Please confirm the Solicitation Pricing Sheet on page 16 will be updated to only show one (1) Lump Sum Price.

Enter the amount for option 2 on page 16 and enter the lump sum price on page 21.

2. During the Site Visit, we were shown where the permanent backup substation will be built, there was a straight shot from this area to an overhead door and dock area. Will this overhead door and dock area be available for the ready-mix truck so the concrete can be hauled/pumped to the permanent backup substation area to build the concrete housekeeping pad? This can be done during normal work hours. 7:00AM to 4:00PM?

No the warehouse is a secured area, for receiving and delivering medical supplies to the medical center.

3. Please confirm the VA will hire and conduct the Commissioning with General Contractor assisting.

No please refer to the specifications.

4. Please confirm height for Wall Type A per Drawing A-103.

Floor to ceiling height is 13' 2"

- May the Project Superintendent also be the SSHO and CQC Systems Manager?Yes
- 6. Does the VA expect the Project Manager to be on site full time? Yes, please refer to the specifications and SOW.
- 7. Please confirm that all personnel that are contracted to this Project must have a tuberculosis screening.

Not Required

8. What level of finish is required for the ICRA wall?

Level 4 Paintable

9. Regarding the concrete housekeeping pad, walls, etc. for the additional substation, can these tasks be performed soon after Notice to Proceed as long as the Type A ICRA wall is constructed?

Refer to the SOW for Baseline construction schedule, safety coordination meetings,

10. Regarding Drawing A-102, the shown ICRA walls, what Type are required, hard or poly?

Refer to SOW (17 Airborne Dust Control During Construction)

End of Document