

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF 2	PAGES
2. AMENDMENT/MODIFICATION NUMBER 0004		3. EFFECTIVE DATE 02-27-2025		4. REQUISITION/PURCHASE REQ. NUMBER		
5. PROJECT NUMBER (if applicable) 595-25-102		6. ISSUED BY CODE 00244 Department of Veterans Affairs Network Contracting Office 4		7. ADMINISTERED BY (If other than Item 6) CODE 00244 Department of Veterans Affairs Network Contracting Office 4		
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders		(X)		9A. AMENDMENT OF SOLICITATION NUMBER 36C24425R0006		
		<input checked="" type="checkbox"/>		9B. DATED (SEE ITEM 11)		
		<input type="checkbox"/>		10A. MODIFICATION OF CONTRACT/ORDER NUMBER		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
<input type="checkbox"/>						
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment to project number 595-25-102 Replace Multi-Stack is as follows: 1) Respond to Requests for Information and provide requested documentation 2) Distribute the Site Visit Sign-In from 2/25/2025						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)				
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  (Signature of Contracting Officer)		
16C. DATE SIGNED						

- 1) For the controls portion, is the requirement simply an integration of the new chiller not the existing BAS or is the entire BAS to be replaced?
  - a. All building automation controls shall be replaced with Distech Controls and shall be integrated into the campus Tridium Niagara, Distech Controls server. Only authorized Distech Controls vendors are permitted.
- 2) Is there glycol in the system? If so, we need to know which manufacturer and product number.
  - a. Yes, the current system does have Glycol. The current heat pump system requires 15% Glycol as listed on drawing MH602 on previously provided mechanical drawings located in the heat pump schedule.
- 3) It was mentioned the unit never worked properly. What issues were experienced with its operation?
  - a. See attached documents
- 4) Please provide list of service history on the unit.
  - a. See attached documents
- 5) Are as-built drawings available to verify location and sizing of other mechanical systems including the geothermal field?
  - a. See attached documents
- 6) Does the VA have any additional drawings or as-builts that it can share with us? Thank you.
  - a. See attached documents

See attached document: 2017 09 25 Field Report.

See attached document: 2017 09 26 Field Report.

See attached document: 2017 09 27 Field Report.

See attached document: 2017 10 21 Field Report.

See attached document: 2017 12 20 Field Report.

See attached document: 2018 01 30 Field Report.

See attached document: 071-087 Mechanical w Addm1.

See attached document: Existing Trane MultiStack.

See attached document: 595-25-102 Replace Multi Stack Building 37 -Phase II - Sign In Sheet.

End of Document