



August 1, 2023

Department of Veterans Affairs
Lebanon VA Medical Center
1700 South Lincoln Avenue
Lebanon, PA 17042-7529

Attention: Ms. Kelly Fields

Reference: Three-Year Reinspection
Lebanon VA Medical Center – **Building 23**
1700 South Lincoln Avenue, Lebanon, PA 17042-7529
Criterion's Project No. **231884**

Dear Ms. Fields,

On July 18, 2023, an inspector from Criterion Laboratories, Inc. (Criterion) completed the three-year reinspection of Building 23 located at the Lebanon VA Medical Center. All identified and assumed asbestos-containing materials (ACM) identified during Criterion's 2015 initial inspection were visually reinspected according to 40 CFR Part 763 to determine their condition. If a change in condition had taken place since the 2018 re-inspection, the material was reassessed and evaluated.

Generally, the remaining ACM observed during our reinspection are in good condition with exceptions noted in our attached response action and assessment forms. We recommend that the response actions be followed as stated.

The attached response actions and assessment forms should be kept with the original inspection documents in a Management Plan. Criterion's certifications are also included.

If you have any questions regarding this report, please do not hesitate to contact me at (215) 244-1300, extension 1039.

Very truly yours,

Craig Gratz, CHMM
Pennsylvania-licensed Building Inspector - PA #050059
Pennsylvania-licensed Management Planner - PA #050059

Attachments

RESPONSE ACTIONS / ASSESSMENT FORMS

RESPONSE ACTIONS

SITE LOCATION: Department of Veterans Affairs
Lebanon VA Medical Center
1700 South Lincoln Avenue
Lebanon, PA 17042-7529

BUILDING: Building 23

Location and Description	Response Action
Block Pipe Insulation <ul style="list-style-type: none">Basement – Crawl Space	All material has been removed.
Compressed Paper Pipe Insulation <ul style="list-style-type: none">Basement – Crawl Space	All material has been removed.
9"x9" Floor Tile and Mastic <ul style="list-style-type: none">1st Floor – Room 123, 124A, 121, 126, 127, 128, 129, 115, 114A, 114, 103, 104, 113, 106, Hallway	Materials appear to have been removed but may be under new flooring. Operations & Maintenance (O&M)
Brown Flooring Material <ul style="list-style-type: none">1st Floor – Room 123, 124, Suite 113 Area	Materials appear to have been removed but may be under new flooring. O&M

CERTIFICATIONS



21 02501700744
23094



If found, please contact:

Department of Labor & Industry
Certification, Accreditation & Licensing Division
651 Boas Street, Room 1606
Harrisburg, PA 17121.
(717) 772-3396



21 02501048905
23094



If found, please contact:

Department of Labor & Industry
Certification, Accreditation & Licensing Division
651 Boas Street, Room 1606
Harrisburg, PA 17121.
(717) 772-3396