

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE 1 OF 2 PAGES

2. AMENDMENT/MODIFICATION NUMBER
00073. EFFECTIVE DATE
03-06-2025

4. REQUISITION/PURCHASE REQ. NUMBER

5. PROJECT NUMBER (if applicable)
595-24-1066. ISSUED BY
Department of Veterans Affairs
Network Contracting Office 4

CODE

00244

7. ADMINISTERED BY (If other than Item 6)

CODE

00244

Department of Veterans Affairs
Network Contracting Office 4

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

36C24425R0008

9B. DATED (SEE ITEM 11)
10-18-2024

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

 A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: D. OTHER (Specify type of modification and authority)**E. IMPORTANT:** Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The above numbered solicitation for Replace Steam Traps Phase One DB is modified to reflect the following:

This is an amendment to provide the remaining responses to RFI's submitted on 24 February 2025 and updated Price Cost Schedule.

See page 2 for RFI responses.
See attached document for updated Price Cost Schedule.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

Christopher McDevitt
Contracting Officer

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

(Signature of Contracting Officer)

#	Question	VA Final Answer
15	Can stainless steel or non-domestic steel be provided in lieu of domestic steel? Domestic cast iron is available but is not allowed per the specification.	Steam traps must be of stainless steel construction, carbon steel body with stainless steel internals is also acceptable and must be American Made
16	During the site visit it was apparent that along with the existing steam traps, most of the pipe fittings and components in each steam trap station were not steel construction. Per the scope of work steel is required. Is the contractor required to replace all the items in the steam trap station that do not meet current VHA material requirements or just the items required to replace the steam traps?	Pipe fittings and components must be steel and meet the Buy American Act. FOR YOUR PRICE PROPOSAL ASSUME ONLY THE STEAM TRAP WILL BE REPLACED. Provide a cost per each type of fitting to be used as a basis of any potential changes to pricing: T-fitting, Elbow, Union and hand valve.

See attached document: Revised Price Cost Schedule.

End of Document